PRECAUTIONARY BOIL WATER NOTICE FOR MILLIGAN WATER SYSTEM, INC. CUSTOMERS IN BAKER, FLORIDA



Contact: Ryan Mims <u>HealthyOkaloosaPIO@flhealth.gov</u> Office: (850) 344-0571 Cell: (850) 420-2198

Baker, Fla – Due to a major water line break in the Milligan Water System, the Florida Department of Health in Okaloosa County (DOH-Okaloosa) is advising residents who are customers of Milligan Water System to take precautions against unclean water. Because of the compromise, any household or business serviced by Milligan Water System may have water that is not safe to drink.

DOH-Okaloosa recommends one of the following for all customers of Milligan Water System:

- Boil water before use, holding it at a rolling boil for at least 1 minute before using it for drinking, cooking, making ice, brushing teeth, or washing dishes; or
- Disinfect water by adding 8 drops (about 1/8 teaspoon this would form a puddle about the size of a dime) of plain unscented household bleach (4 to 6 percent active ingredients) per gallon of water and then let it stand for 30 minutes. If the water is cloudy after 30 minutes, repeat the procedure. Use a container that has a cap or cover for disinfecting and storing water to be used for drinking. This will prevent contamination; or
- Use bottled water, especially for mixing baby formula.

This precautionary boil water notice will remain in effect until the problem has been corrected and a bacteriological survey shows that the water is safe to drink.

For more information, go to Milligan Water System's website at <u>www.milliganwatersystem.com</u> or call 850-537-9131.

About the Florida Department of Health

The department, nationally accredited by the <u>Public Health Accreditation Board</u>, works to protect, promote and improve the health of all people in Florida through integrated state, county and community efforts.

Follow us on Twitter at <u>@HealthyFla</u> and on <u>Facebook</u>. For more information about the Florida Department of Health, please visit <u>www.FloridaHealth.gov</u>.